



Safety & Buildings Division
201 West Washington Ave.
P.O. Box 2658
Madison, WI 53701-2658

Approval #
New Product #
201117-O
Replaces 200617-O
File No. 20119017

Wisconsin Building Products Evaluation

Material

Inclined Ladder for Access to an Exterior Press Box

Manufacturer

Southern Bleacher Company, Inc.
P.O. Box One / 801 Fifth Street
Graham, TX 76450

SCOPE OF EVALUATION

GENERAL: This approval evaluates the use of an inclined ladder for access to an exterior press box, manufactured by Southern Bleacher Company, Inc.

The **IBC** requirements below in accordance with the current **Wisconsin Amended ICC Code**:

- **Non-Code Compliant Stair:** The inclined ladder for access to an exterior press box was evaluated in accordance with the requirements of **s. IBC 1009.4.2**.

DESCRIPTION AND USE

The metal ladder placed at a 60° angle is 8' – 7 1/2" in height, 2'- 0" wide, the rungs are 6" wide and the riser height is 12 inches. Railings on both sides of the ladder begin at the third rung and consist of 1-1/4" SCH 40 pipe. See Figure on page two.

LIMITATIONS OF APPROVAL

The **IBC** limitations below are in accordance with the current **Wisconsin Amended ICC Code**:

Where an accessible route is not required, this product may be used to access the roof of a press box for maintenance and filming of games by no more than two persons, as indicated by a sign posted in a conspicuous location. The usable area of the roof and delineated with guardrails shall not exceed 250 square feet.

If a more extensive use is needed, an alternating tread device will be allowed to serve five people.

